

**Mandatory Language for a Maximum Contaminant Level Violation  
MCL, AVERAGE / ARSENIC**

The Texas Commission on Environmental Quality (TCEQ) has notified the Leroy-Tours-Gerald WSC TX1550027 that the drinking water being supplied to customers had exceeded the Maximum Contaminant Level (MCL) for arsenic. The U.S. Environmental Protection Agency (U.S. EPA) has established the MCL for arsenic to be 0.010 milligrams per liter (mg/L) based on a running annual average (RAA), and has determined that it is a health concern at levels above the MCL. Analysis of drinking water in your community for arsenic indicates a compliance value in quarter one 2018 of 0.013 mg/L for EP001 and 0.012 mg/L for EP003.

This is not an emergency. However, some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

You do not need to use an alternative water supply. However, if you have health concerns, you may want to talk to your doctor to get more information about how this may affect you.

We are taking the following actions to address this issue:

The Leroy-Tours-Gerald WSC is a member of the FHLM Regional WSC, and it is negotiating to purchase treated drinking water for its members. This water will be blended with our Corporation's water to lower the arsenic content to a level that complies with the MCL for arsenic.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in public places or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact the Leroy-Tours-Gerald WSC Office at 254-822-1343, Barry Hand, Manager/Operator

Posted/Delivered on:05/15/2018